

ServiceChecker Demo (Fire Ext)

Fire Extinguisher

Fire Extinguisher Exception Report

01/28/19 12:00 AM Through 01/28/19 11:59 PM

Reporting only maintenance items with problems

OBSERVATION TABLE:

Group	Symbol	Value	Description
01	P	Positive	1a. Access to FE is NOT blocked
	N	Negative	1b. Access to FE is blocked
02	P	Positive	2a. FE gauge is Green
	N	Negative	2b. FE gauge is NOT Green
03	P	Positive	3a. FE tag is current
	N	Negative	3b. FE Tag is NOT current

Description	Scan			Condition	Date	Time	Person
	Rqrd	Group	Value				
FE 01	Yes	01	N	1b. Access to FE is blocked	01/28/19	11:34 AM	Sally Jones
		02	P	2a. FE gauge is Green			
		03	P	3a. FE tag is current			
FE 04	Yes			(Not Scanned)			

